

1. Manufactured and certified by	Cryolor Asia Pacific Pvt Ltd No 1, GST Road Chennai-Madurai NH45 Kadamalaiputhur Village Perumberkandigai Post Maduranthagam Taluk, Tamilnadu 603310 India					
	(Name and address of Manufacturer)					
2. Manufactured for	Stock					
	(Name and address of Purchaser)					
3. Location of installation	Not known					
	(Name and address)					
4. Type	Vertical	C250006	NA	Refer Form U-4	254	2021
	(Horizontal or vertical, tank)	(Manufacturer's serial number)	(CRN)	(Drawing number)	(National Board number)	(Year built)
5. ASME Code, Section VIII, Division 1	2019		None		Low Temperature-320°F (-196°C)	
	[Edition and Addenda, if applicable (Date)]		(Code Case numbers)		[Special Service per UG 120(d)]	
6. Shell	SA-240M Type 304	0.535 In. (13.6mm)	0.0In. (0.0 mm)	94.488 In. (2400 mm)	344.763In. (8757 mm)	
	(Material spec. number, grade)	(Nominal thickness)	(Corr. allow.)	(Inner Diameter)	[Length (overall)]	

[illegible]

7. Seams	Type 1 dbl Butt	Full	1.0	None	None	Refer Form U-4	Full	0.9,1.0	6
	[Long. (welded, dbl., singl., lap, butt)]	[R.T. (Spot or Full)]	[Eff. %]	[H.T. Temp.]	[Time, hr]	[Girth (Welded, Dbl., Singl., Lap, Butt)]	[R.T. (Spot or Full)]	[Eff.]	[No. of Courses]

8. Heads: (a) Material	SA-240M Type 304 (Spec. no., grade)	(b) Material	SA-240M Type 304 (Spec. no., grade)
------------------------	--	--------------	--

	Location (Top, Bottom, Ends)	Minimum Thickness (mm)	Corrosion Allowance (mm)	Crown Radius (mm)	Knuckle Radius (mm)	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius (mm)	Flat Diameter (mm)	Side to Pressure (Convex or Concave)
(a)	Top End	0.535 In. (13.6mm)	0.0 In. (0.0 mm)	NA	NA	2:1	NA	NA	NA	Concave
(b)	Bottom End	0.535 In. (13.6mm)	0.0 In. (0.0 mm)	NA	NA	2:1	NA	NA	NA	Concave

[illegible]

9. MAWP	350psig (2.413Mpa)	NA	at max. temp.	120°F (50°C)	NA
	(Internal)	(External)		(Internal)	(External)
Min. design metal temp.	-320°F (-196°C)	at 350psig (2.413Mpa)	Hydro., pneu. or comb. test pressure		Cold Stretching Pressure 580.151Psig (4.0 MPa)
Proof test	NA				

10. Nozzles, inspection, and safety valve openings:

[illegible]

11. Supports: Skirt	No (Yes or no)	Lugs	NA (Number)	Legs	NA (Number)	Other	Refer Form U-4 (Describe)	Attached	Refer Form U-4 Remarks (4) (Where and how)
---------------------	-------------------	------	----------------	------	----------------	-------	------------------------------	----------	---

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: NA
(Name of part, item number, Manufacturer's name and identifying stamp)

This Vessel has been constructed using Cold-Stretching Process in accordance with Mandatory Appendix 44, Hence 'CS' marked on Code Name plate.

National Board Number: 254
 Mfg. Representative: U. J. P. D. Date: 01/MAR/2021
 Authorized Inspector: Sureshkumar Date: 01/MAR/2021

FORM U-1A

Manufactured by Cryolor Asia Pacific Pvt Ltd No 1, GST Road Chennai-Madurai NH45 Kadamalaiputhur Village Perumberkandigai Post

Maduranthagam Taluk, Tamilnadu 603310 India

Manufacturer's Serial No C250006 CRN N.A National Board No. 254

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 43,832 expires September 28, 2021

Date 01/MAR/2021 Co. name Cryolor Asia Pacific Pvt Ltd Signed U. J. P. D.
 (Manufacturer) (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Cryolor Asia Pacific Pvt Ltd at address specified in SI. No.1

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by TÜV SÜD Industrie Service GmbH of Westendstrasse 199, 80686 Munich, Germany

have inspected the component described in this Manufacturer's Data Report on 13-Feb-2021, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date: 01/MAR/2021 Signed Sureshkumar Sozhan Commissions NB 15133 AI
 (Authorized Inspector) (National Board Authorized Inspector Commission number)

National Board Number : 254
Mfg. Representative: U. J. S. D. Date: 01/MAR/2021
Authorized Inspector: Sureshkumar Sozhan Date: 01/MAR/2021

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by Cryolor Asia Pacific Pvt Ltd No 1, GST Road Chennai-Madurai NH45 Kadamalaiputhur Village Perumberkandigai Post Maduranthagam Taluk, Tamilnadu 603310 India

(Name and address of Manufacturer)

2. Manufactured for Stock

(Name and address of Purchaser)

3. Location of installation Not known

(Name and address)

4. Type : Vertical Pressure Vessel C250006
(Horizontal, vertical, or sphere) (Tank separator, heat exch., etc.) (Manufacturer's serial number)
N.A. HC003650 Rev.AB 254
(CRN) (Drawing number) (National Board Number) (Year built)

Data Report
(Item Number)

Remarks

7.

[Girth (Welded, Dbl, Single, Lap., Butt)]	[R.T. (Spot or Full)]	[Eff. (%)]
Shell to Shell Type-1 Double Butt	Full	1.0
Shell to Head Type-2 Single Butt	Full	0.9

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain etc.)	Number	Diameter or Size (In.)	Type	Material		Nominal Thickness (In.)		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom	Corr		Nozzle	Flange	
Top Filling Cum Trycock(T1-1)	1	OD 2.375	w.e	SA-312M TP304	-	0.154	0	-	Fig UW-16.1(e)	-	-
Safety Line(T2)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-
High Level(Gas) (T4)	1	OD 0.840	w.e	SA-312M TP304	-	0.109	0	-	Fig UW-16.1(e)	-	-
Hydro Piping(T5)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-
Gas Return-1(T6-1)	1	OD 2.375	w.e	SA-312M TP304	-	0.154	0	-	Fig UW-16.1(e)	-	-
Gas Return-2 (T7)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-
Condenser Feeding(T8)	1	OD1.050	w.e	SA-312M TP304	-	0.113	0	-	Fig UW-16.1(e)	-	-
Condenser Return(T9)	1	OD 1.050	w.e	SA-312M TP304	-	0.113	0	-	Fig UW-16.1(e)	-	-
Gas Return-3 (T10)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-
Liquid Withdrawal (B1-1)	1	OD 2.375	w.e	SA-312M TP304	-	0.154	0	-	Fig UW-16.1(e)	-	-
Bottom Filling(B2-1)	1	OD 2.375	w.e	SA-312M TP304	-	0.154	0	-	Fig UW-16.1(e)	-	-
Liquid Withdrawal(B3-1)	1	OD 2.375	w.e	SA-312M TP304	-	0.154	0	-	Fig UW-16.1(e)	-	-
Low Level(Liquid)(B4)	1	OD 0.840	w.e	SA-312M TP304	-	0.109	0	-	Fig UW-16.1(e)	-	-
Hydro Piping(B5)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-
Liquid Withdrawal(B10)	1	OD 1.900	w.e	SA-312M TP304	-	0.145	0	-	Fig UW-16.1(e)	-	-

- Impact testing exempted for base metal and HAZ as per UHA-51(d)(1)(a) & Mandatory Appendix 44 clause 44-6.1(g)(1).
Welding Procedure are Impact tested at -196°C for weld & HAZ as per UHA 51(e)(2)(a) & Mandatory Appendix 44 clause 44-6.1(g)(2)
- Vessel Model No.: RCIA50
- "For Non Corrosive Service" - No corrosion allowance considered in design. Hence no inspection opening provided.
- Four Main supports welded on OD of Shell at 35° between axis Y0-X0, Y1-X1, X0-Y1 & X1-Y0 at 34.252 In. from top head to shell weld line. Three Leg welded with outer vessel shell bottom at location 10° from axis (Y1-X1), 45° from axis (Y0-X1), and 80° from axis (Y0-X0).
- Duplicate Code name plate provided on outer vessel with nameplate bracket at 2.755 In. from bottom weld line axis 26° from X1-Y0.
- Liquid penetrant examination performed on all categories A, D welds & attachment welds after Cold Stretch of the vessel
- Pre-use testing of welding consumables performed as per UHA-51(f).
- Vessel is insulated and enclosed within outer vessel constructed of carbon steel material.
- Code Name plate tack welded on name plate support rod at a distance of 1.969 In. from nozzle no. T1 center line and 30° between axis (X0-Y1) on Top head.
- 'NA' Indicates as 'Not Applicable', 'OD' - Outside Diameter, 'w.e' - Weld End, 'ID' - Inside Diameter

Certificate of Authorization: Type U No. 43.832

Expires September 28, 2021

Date 01/MAR/2021 Name: Cryolor Asia Pacific Pvt Ltd

Signed N. J. S. D.

(Manufacturer)

(Representative)

Date 01/MAR/2021 Signed Sureshkumar Sozhan

Commissions NB15133 AI

(Authorized Inspector)

(National Board Authorized Inspector Commission number)

